

600S125-30 DW30 (Standard Punch)



Product Description: 6" Track 20GA (1 1/4" Leg, 30mil)

Coating: G60 (standard), G90 (special order)

Specification Section: 09.22.16 (Non-Structural Metal Framing)

GEOMETRIC PROPERTIES			
Web Depth	6 in.	Yield Strength, Fy	33 ksi
Flange Width	1.25 in.	Design Thickness	0.0312 in.
Lip Length	0.188 in.	Min. Design Thickness	0.0296 in.

GROSS PROPERTIES		
Area (in ²)	Total cross-sectional steel area	0.268
Weight (lb/ft)	Linear weight per foot	0.91
I _x (in ⁴)	Moment of inertia about the x-axis	1.276
S _x (in ³)	Section modulus about the x-axis	0.425
R _x (in)	Radius of gyration about the x-axis	2.182
I _y (in ⁴)	Moment of inertia about the y-axis	0.038
R _y (in)	Radius of gyration about the y-axis	0.376
EFFECTIVE PROPERTIES		
I _x (in ³)	Effective moment of inertia (x-axis)	1.222
S _x (in ³)	Effective section modulus (x-axis)	0.304
M _a (in-k)	Allowable bending moment-effective section modulus	6.00
M _{ad} (in-k)	Allowable bending moment-distortional buckling	4.91
V _{a_g} (lb)	Allowable shear force in web	468
V _{a_{net}} (lb)	Allowable strong axis shear at punchout	468
TORSIONAL PROPERTIES		
J x 1000 (in ⁴)	St. Venant torsional constant	0.087
C _w (in ⁶)	Warping constant	0.274
X _o (in)	Distance from shear center to centroid	-0.611
m (in)	Distance from shear center to mid-plane of web	0.401
R _o (in)	Polar radius of gyration	2.297
Beta	Torsional Flexural Constant	0.929



Non-structural punchout first punchout is centered 12" from beginning of member; subsequent punchouts are 24" on center (o.c.).
Center of last punchout is no less than 12" from end of member.

CODES AND STANDARDS:

Super Stud products comply with the applicable provisions of the following:

- International Building Code (IBC): 2006 – 2024
- Complies with AISI S100-16 (2020) w/S2-20. Effective properties incorporate the strength increase from the cold work of forming
- Sheet steel: ASTM A1003/A1003M; ASTM A653/A653M
- Galvanized coating: ASTM A653/A653M or equivalent
- UL Designs: U419, V438, V489, V498, W433, W440
- Tested in accordance with ASTM E119; ANSI/UL 263
- Members and tolerances: ASTM C645; AISI S220, AISI S201, AISI S202
- Meets ASTM C754 when installed properly in structure

For LEED Letter requests please submit through: www.buysuperstud.com

NEW HAMPSHIRE FACILITY
12 TALLWOOD DRIVE
BOW, NH 03304
P: 603-216-1573

MISSISSIPPI FACILITY
53 W L RUNNELS IND DR
HATTIESBURG, MS 39401
P: 601-584-7550

NEW JERSEY FACILITY
2960 WOODBRIDGE AVE
EDISON, NJ 08837
P: 732-662-6200